

2010 Fire Alarm Log
(updated weekly)

Incident Date	Building	Incident Description	Incident Details
1/5/2010 12:38	Schlosser Residence Hall	Alarm Fire Detection System Malfunction	CO detector set off fire alarms. Panel would not reset. No apparent reason for alarm. Disabled CO detector and reset.
1/6/2010 20:55	Schreiber Quadrangle	Alarm Fire Simplex System	Alarm activated by stove being left on in building. Reset alarm.
1/11/2010 15:01	Schlosser Residence Hall	Alarm Fire	Schlosser mechanical room CO detector activated. Detector disabled and Simplex contacted.
1/23/2010 22:43	Hackman House 530 S Mt Joy St	Fire (No EMS or Simplex message)	Stove fire activated alarm. Students put out fire with extinguisher.
1/28/2010 20:40	Vera Hackman Apartments	Alarm Fire Simplex	Alarm activated in Hackman due to cooking. Alarm reset.
1/31/2010 12:26	Rose Garden 320 East Orange Street	Alarm Fire Simplex System	Smoke detector activated in Rose Garden room 21. Reason unknown. Panel reset.
2/3/2010 0:03	Ober Residence Hall	Alarm Fire Trouble Simplex System	Ober ground floor smoke detector activated due to dirty detector.
2/3/2010 1:05	Brossman Commons	Alarm Fire Trouble Simplex System	Battery default reset at panel in BSC.
2/4/2010 0:00	Ober Residence Hall	Alarm Fire Simplex System	Smoke detector activated by burnt popcorn. System reset.
2/5/2010 5:55	Vera Hackman Apartments	Alarm Fire Trouble Simplex	Alarm activated by cooking in Hackman. System reset.
2/5/2010 15:27	Baugher Student Center	Alarm Fire Simplex System	Fire detector activated in kitchen. No fire aor smoke present. Alarm would not reset. Detector was deactivated.
2/5/2010 18:00	Vera Hackman Apartments	Alarm Fire Simplex	Alarm detector activated in bedroom of Hackman S. Detector replaced.
2/6/2010 7:21	Vera Hackman Apartments	Alarm Fire Reported by Person	Alarm going off in VHAS 308. No smoke or fire. Going off all night. CSO disconnected the alarm in bedroom.
2/6/2010 20:22	Royer Residence Hall	Alarm Fire Simplex	Alarm activated by student using hair straightener under detector.
2/8/2010 13:03	Founders Residence Hall	Alarm Fire Simplex System	FH Bwing detector activated. Would not reset. Notified Plant Ops.
2/9/2010 7:29	High Library	Alarm Fire EMS Computer	High Library smoke detector activated. Maintenance tech working in power room.
2/13/2010 12:18	Brinser Residence Hall	Alarm Fire Simplex System	Smoke detector in Brinser activated by burnt food. Reset alarm.
2/13/2010 14:52	Leffler Chapel	Alarm Fire EMS Computer	Child pulled fire alarm at chapel in main lobby. Pull station and panel reset.
2/13/2010 20:56	Myer Residence Hall	Alarm Fire Simplex System	Myer first floor smoke detector activated by cooking. Alarm reset.
2/14/2010 12:38	Royer Residence Hall	Alarm Fire Simplex System	Smoke detector in Royer 3rd floor activated by burnt popcorn. Panel reset.
2/17/2010 8:49	Royer Residence Hall	Alarm Fire Simplex System	Kitchenette in Royer smoke detector activated. Nothing found. Panel reset.
2/19/2010 18:35	Founders Residence Hall	Alarm Fire Trouble EMS System	FH Dwing 3rd floor detector activated. No alarm present. Detector had been located by system and cleared itself.
2/19/2010 23:33	Maple House 435 College Aveune	Alarm Fire Simplex System	CO2 detectors had been bumped in 435 Maple House activating alarm system.
2/21/2010 17:02	Cedar House 625 S Mt Joy St	Alarm Fire Simplex System	Shower steam set off alarm at Cedar House. Panel reset.
2/21/2010 18:00	Vera Hackman Apartments	Alarm Fire Trouble Simplex System	Hackman North smoke detector activated by cooking. Alarm reset.
2/22/2010 10:59	Founders Residence Hall	Alarm Fire Simplex System	Smoke detector activated in Founders. Head replaced. System reset.
2/24/2010 22:44	Baugher Student Center	Alarm Fire Simplex System	Alarm activated in BSC. Reset.
2/27/2010 16:51	Myer Residence Hall	Alarm Fire Simplex System	Smoke detector activated by students cooking in kitchen. Alarm reset.
2/27/2010 17:49	Vera Hackman Apartments	Alarm Fire Simplex System	Smoke detector activated. System normal when officer arrived. System reset.
3/3/2010 20:17	Baugher Student Center	Alarm Fire Simplex	BSC concourse rescue assist alarm activated. System reset.
3/7/2010 17:06	Lake Placida	Fire (No EMS or Simplex)	A person from town called to say that someone was trying to start a fire at the lake near the Young Center.
3/10/2010 13:07	Off Campus	Alarm Fire Drill	Tested fire alarms for semester test.
3/20/2010 21:15	Ober Residence Hall	Alarm Fire Simplex System	Smoke detector activated by burnt popcorn.
4/11/2010 13:00	Myer Administration	Alarm Fire Simplex System	Myer 1st floor Susquehanna detector activated by balloons. CSO reset panel and temporarily disabled beam detector so alarm would not go off again .
4/13/2010 11:28	Vera Hackman Apartments	Alarm Fire Simplex System	Smoke detector activated in VHAN 152 due to burnt food. Panel reset.
4/18/2010 17:13	White House 540 S Mt Joy St	Alarm-Fire, Simplex System	White House carbon-monoxide detector activated. Alarm disabled. MTOC contacted.
4/20/2010 16:40	Brinser Residence Hall	Alarm Fire Simplex System	Shower steam and mist caused alarm to activate in Brinser.
4/20/2010 18:31	Vera Hackman Apartments	Alarm Fire Simplex System	Alarm activated in Hackman by burnt food. System reset.
4/21/2010 15:09	Vera Hackman Apartments	Alarm Fire Simplex System	Smoke detector activated by dirty burner on stove. CSO reset panel.
4/26/2010 16:13	Schreiber Quadrangle	Alarm Fire Simplex	Shower steam set off alarm. Panel reset.
4/29/2010 9:41	Schreiber Quadrangle	Alarm Fire Simplex System	Smoke detector activated at Quad by shower steam. System reset.
5/11/2010 23:59	Ober Residence Hall	Alarm-Fire Simplex	Alarm activated by burnt popcorn.
5/12/2010 2:16	Myer Residence Hall	Alarm Fire Trouble	Alarm activated by burnt playing cards on toaster. Toaster was removed and taken to Security.
5/19/2010 15:44	Brinser Residence Hall	Fire Alarm Simplex System	Heat detector activated by chemicals sprayed near alarm. Alarm reset.
5/22/2010 9:25	Schreiber Quadrangle	Alarm Fire Simplex System	Smoke detector activated by humidity.
5/30/2010 6:13	Myer Residence Hall	Alarm Fire Simplex System	Alarm activated by steam from shower.
6/5/2010 14:33	Hackman House 530 S Mt Joy St	Alarm Fire Simplex System	Alarm activated in Hackman Gables due to dust from workers.
6/8/2010 23:45	High Library	Alarm Fire EMS System	High Library fire alarm activated for no aparent reason. Alarm reset.
6/14/2010 10:37	Founders Residence Hall	Alarm Fire Simplex	Contractor set off alarm in Founders Cwing.
6/16/2010 9:36	Lyet	Alarm Fire Trouble	Smoke detector activated in Lyet. No problems found.
6/21/2010 19:38	Leffler Chapel	Alarm Fire Reported by Person	RP called to report fire alarm going off in chapel. CSO found no cause for alarm. System reset.
6/23/2010 8:25	Brinser Residence Hall	Alarm Fire Simplex System	Alarm activated due to removal of ceiling panels. System reset.
6/28/2010 21:12	Lyet	Alarm Fire Simplex System	Smoke detector activated in Lyer wing, 2nd floor, 251 A. Caused by water seeping through ceiling. Smoke detector head deactivated.

2010 Fire Alarm Log
(updated weekly)

Incident Date	Building	Incident Description	Incident Details
6/29/2010 10:20	Myer Administration	Alarm Fire Reported by Person/Alarm Mechan	ES worker called to reported they set off fire alarm but nothing came over our systems.
7/2/2010 15:49	Steinman Hall	Alarm-Fire EMS Computer	Alarm activated by dust in art studio area from student cleaning. Panel reset.
7/5/2010 9:12	High Library	Alarm Fire EMS Computer	Alarm activated. MTOC had turned off air handlers and a duct detector which set off trouble alarm.
7/11/2010 11:31	Royer Residence Hall	Alarm Fire Simplex System	Alarm activated in Royer 228. Nothing found. Alarm reset.
7/12/2010 18:28	Rose Garden 320 East Orange Street	Alarm Fire Simplex System	Defective alarm in Rose Garden bedroom. Needs to be replaced.
7/13/2010 14:30	Brinser Residence Hall	Alarm Fire Simplex	Fire alarm activated in Brinser. No apparent cause other than ES cleaning.
7/13/2010 17:46	Musser Hall	Alarm Fire Simplex System	Smoke alarm activated by contractors working. Alarm reset.
7/22/2010 15:37	Steinman Hall	Alarm Fire Reported by Person	Alarm set off by student mixing powder and sand for sculpture. Panel reset.
7/24/2010 22:08	Leffler Chapel	Alarm Fire Trouble EMS System	Leffler Chapel fire trouble. CSO checked alarms and will advise CSO #1 in AM.
7/25/2010 9:56	Leffler Chapel	Alarm Fire EMS System	Child pulled pull station Leffler Chapel activating alarm. Water leak spotted in 2nd floor closet. MTOC contacted.
7/28/2010 8:28	Leffler Chapel	Alarm Fire Trouble	Alarm going off in chapel. CSO disabled detector head. Simplex will need to look at it.
8/1/2010 13:36	Maple House 435 College Aveune	Alarm Fire Simplex System	Maple House fire alarm monitor activated. Nothing found. Panel Reset.
8/4/2010 8:38	Founders Residence Hall	Alarm Fire Simplex System	Smoke detector activated in Founders. CSO found spider inside detector head. Head was replaced and panel was reset.
8/10/2010 19:24	Vera Hackman Apartments	Alarm Fire Simplex System	Fire alarm activated in Hackman third floor stairwell. Students were evacuated. No fire present. Alarm was silenced and system was reset. Students returned to building.
8/16/2010 18:13	Leffler Chapel	Alarm Fire Trouble EMS System	Report of alarm buzzing. Alarm was actually fire troubles. Four new trouble alarms on panel at chapel. Appears chapel may have been hit during electrical storm.
8/17/2010 13:05	Myer Residence Hall	Alarm Fire Simplex System	Alarm activated in Myer by dust from concrete blocks being cut by construction company. Panel reset.
8/20/2010 7:32	Vera Hackman Apartments	Alarm Fire Simplex System	Supervisory alarm went off in Hackman S. Painters were sanding and activated alarm. Painters finished sanding and alarm was reset.
8/20/2010 13:06	Vera Hackman Apartments	Alarm Fire Simplex	Maintenance tech on call called security and stated that he believed he had set off alarm with fan blowing dust in hallway. System reset.
8/21/2010 9:08	Vera Hackman Apartments	Alarm Fire Trouble Simplex System	Trouble alarm went into a fire alarm. CSO found mold on smoke detector in living room of Hackman South.
8/22/2010 9:12	Vera Hackman Apartments	Alarm Fire Simplex System	Hackman S. 3rd floor smoke detector activated. Alarm head changed by CSO #1.
8/23/2010 3:48	Vera Hackman Apartments	Alarm Fire Simplex System	Sprinkler monitor/water flow alarm activated in Hackman North. No water found in basement. Simplex contacted. MTOC contacted.
8/23/2010 20:13	Thompson Gymnasium	Alarm Fire EMS Computer	Thompson Gym fire trouble activated. Simplex checking system.
1/25/2010 6:52	Cedar House 625 S Mt Joy St	Alarm Fire Simplex	Smoke detector activated by shower steam. System reset.
4/13/2010 17:16	Brinser Residence Hall	Alarm Fire Simplex System	Fire alarm activated in Brinser 101 by burnt popcorn. Alarm reset.
5/24/2010 23:16	Founders Residence Hall	Fire, Trouble, Simplex System	Dirty smoke detector activated alarm.
	Wenger Center	Alarm Fire Trouble Simplex System	System Supervisory point alarm in Wenger. CSO assisted. Alarm read Wenger Gr. Fl. tamper switch; sprinkler monitor abnormal. It also stated alarm reset.
12/13/2000 13:59	Founders Residence Hall	Alarm Fire, Simplex System	Alarm activated by steam from shower. CSO assisted but alarm would not reset.
8/28/2010 17:46	Royer Residence Hall	Alarm-Fire Simplex System	Alarm/fire on Simplex. No audible report when CSO arrived. System was normal when checked. CSO reset. Possibly activated by steam from shower.
8/30/2010 11:40	Myer Residence Hall	Alarm Fire Simplex System	Contractors in basement of Myer activated alarm system.
8/31/2010 2:03	Schlosser Residence Hall	Alarm Fire	Dirty smoke detector caused activation of alarm in Schlosser.
9/2/2010 10:17	Vera Hackman Apartments	Alarm Fire Simplex System	Burnt food activated alarm in Hackman S 207. CSO reset alarm.
9/5/2010 20:38	Royer Residence Hall	Alarm Simplex Fire	Royer third floor fire alarm activated by steam from shower. CSO reset system.
9/9/2010 16:05	Schlosser Residence Hall	Alarm Fire Simplex System	Student drying her hair in Schlosser set off alarm in her room only. CSO reset panel.
9/10/2010 21:02	Brinser Residence Hall	Alarm Fire Simplex	Fire detector activated by steam from popcorn machine operated by Res. Life.
9/11/2010 1:56	Campus Security	Alarm Fire Simplex System	Pull station pulled. AC on call notified.
9/19/2010 22:58	Schlosser Residence Hall	Alarm Fire-Simplex System	Schlosser smoke detector activated by smoke from student cooking. CSO assisted, opened windows to air room and reset system.
9/21/2010 3:05	Nicarry Hall	Alarm Fire,Trouble EMS System	Alarm activated. CSO responded to Nicarry but no visible or audible alarms found. MTOC contacted.
9/27/2010 17:51	Meyers House 999 College Ave	Fire-Simplex	Myer House fire alarm activated by cooking. System reset.
9/27/2010 19:51	Myer Residence Hall	Alarm Fire Simplex System	Smoke detector in Myer activated by burnt popcorn. System reset by CSO.
9/28/2010 8:05	Brinser Residence Hall	Alarm Fire Simplex	Fire alarm activated in Brinser by steam from shower. CSO reset.
10/2/2010 6:27		Alarm Fire Simplex System	Smoke alarm activated in Schlosser 2nd floor. CSO assisted. Nothing was found.
10/2/2010 22:13	Maple House 435 College Aveune	Alarm Fire-Simplex System	CO2 detector was supposedly activated. CSO assisted but found both detectors were reading normal. It appears one might have been bumped.
10/4/2010 1:47	White House 540 S Mt Joy St	Alarm-Fire,Trouble EMS System	Fire alarm activated at Kessler House. CSO assisted. Nothing found.
10/4/2010 3:11	Leffler House (Admissions House)	Alarm Fire Trouble, EMS System	Fire trouble alarm activated in Leffler House. CSO assisted but found nothing.
10/5/2010 0:17	Vera Hackman Apartments	Alarm Fire Simplex System	HN second floor smoke detector activated. CSO found no cause for alarm. CSO reset system.
10/5/2010 4:09	Maple House 435 College Aveune	Alarm Fire Simplex System	Audible and visual alarms in Maple House. CSOs assisted but found not cause for alarm.
10/5/2010 13:55	Vera Hackman Apartments	Alarm Fire Simplex	Alarm activated by cooking smoke from grease. CSO assisted, aired out room and reset alarm.
10/5/2010 19:36	Schlosser Residence Hall	Alarm Fire Simplex System	Smoke detectors activated by steam from cooking. CSO assisted and reset alarm.
10/7/2010 6:02	Vera Hackman Apartments	Alarm Fire Simplex System	Fire alarm activated in VHS 205. CSO assisted but found no reason for alarm. System reset.
10/10/2010 19:49	Campus Security	Alarm- Fire EMS	Computer showing alarms for Rose Garden and Kessler House, but no alarm at either house.
10/14/2010 6:06	Leffler House (Admissions House)	Alarm Fire, Trouble EMS System	Leffler House sump pump alarm activated. CSO assisted and found not visual or audible alarms. MTOC contacted.
10/18/2010 0:00	Vera Hackman Apartments	Alarm-Fire, Simplex System	Alarm activated in Hackman S. CSO assisted but found no detector activated. Possibly alarm caused by steam from shower.
10/18/2010 18:28	Schlosser Residence Hall	Alarm-Fire, Simplex	Fire alarm in Schlosser. CSO assisted and found detector activated by blow dryer and hair spray being used by occupant doing hair.

2010 Fire Alarm Log

(updated weekly)

Incident Date	Building	Incident Description	Incident Details
10/21/2010 6:38	Brossman Commons	Alarm Fire Simplex System	Alarm activated in BSC basement. CSOs assisted and found no smoke or fire. MTOC contacted. Alarm reset.
10/22/2010 21:01	Vera Hackman Apartments	Alarm Fire Simplex System	Alarm activated by cooking. Resident removed detector. CSO advised resident not to remove detectors. CSO replaced and reset system.
10/23/2010 13:15	Brossman Commons	Alarm Fire Simplex System	Alarm activated in 2nd floor kitchen of BSC. CSO responded and could not find source of alarm. CSO attempted to reset panel three times but it would not reset. CSO disabled point M1-227 then reset panel.
10/23/2010 19:53	Vera Hackman Apartments	Alarm Fire Simplex System	Alarm activated. CSO assisted and replaced detector.
10/27/2010 7:40	Brinser Residence Hall	Alarm Fire Simplex System	Fire alarm activated in Brinser by steam from shower. CSO assisted and reset alarm.
10/30/2010 7:00	Myer Residence Hall	Alarm Fire Simplex System	Alarm activated in Myer 223 by shower. CSO assisted and reset alarm.
11/3/2010 14:35	Myer Residence Hall	Alarm Fire Simplex	Smoke detector activated by shower. CSO assisted and reset system.
11/3/2010 23:13	Myer Residence Hall	Alarm Fire, Simplex System	Smoke detector activated in Myer 322 due to popcorn being made. CSO assisted and reset.
11/4/2010 16:08	Ober Residence Hall	Fire (No EMS or Simplex Message)	Fire in mechanical room in Ober in heating unit #2. CSO assisted and put fire out with fire extinguisher.
11/10/2010 8:25	Leffler Chapel	Alarm Fire Trouble EMS System	Leffler Chapel fire trouble. CSO's assisted. No "Fire Troubles" showing on panel.
11/10/2010 15:11	Myer Residence Hall	Alarm Fire Simplex	Smoke detector activated in Myer 2nd floor by steam from shower. CSO assisted and reset alarm.
11/14/2010 15:05	Brossman Commons	Alarm Fire Simplex System	Officers responded to Marketplace. Dining services supervisor informed officers that an item caught fire on grill and set off alarm. Dining services supervisor was able to put it out. CSOs reset alarm.
11/17/2010 15:38	Leffler Chapel	Alarm Fire EMS System	Leffler Chapel fire trouble in "Fire Trouble". It is an ongoing issue. Troubles showing in panel.
11/17/2010 17:10	Myer Residence Hall	Alarm-Fire Simplex	Myer 2nd floor smoke detector activated. No problem detected. CSO reset system.
11/19/2010 17:58	Quarry	Fire	RP found unattended fire near quarry in woods. Cinder blocks had been set up for seats. CSO put fire out and searched area finding only a purse. See inc. #10-1775.
11/19/2010 22:31	Sauder House 520 S Mt Joy St	Alarm Fire Trouble	Simplex alarm panel is showing "Trouble 6" on read out. Not showing on panel in office. CSO assisted.
11/30/2010 22:15	Ober Residence Hall	Alarm-Fire, Simplex	Smoke detector activated in Ober due to burnt popcorn.
12/1/2010 13:37	Vera Hackman Apartments	Alarm Fire Simplex	Fire alarm activated by burnt food in VHAN 352. CSOs assisted.
12/5/2010 17:33	Schreiber Quadrangle	Alarm Fire Trouble, Simplex System	Fire alarm activated in Quad. System was normal. Dispatch reset system. CSO silenced alarm at Quads.
12/7/2010 9:51	Myer Residence Hall	Alarm Fire Simplex	Smoke detector activated by steam from shower. CSO assisted.
12/11/2010 5:09	Founders Residence Hall	Alarm-Fire, Trouble, Simplex	Alarm coming from Founders Bwing, shower heat detector due to steam. CSO assisted and reset system.
12/11/2010 11:14	Founders Residence Hall	Alarm-Fire, Trouble Simplex System	Founders Bwing heat detector alarm activated by shower steam. CSO assisted and reset alarm.
12/11/2010 11:35	Myer Residence Hall	Alarm-Fire, Trouble Simplex System	Smoke detector activated due to steam from shower. CSO assisted and reset panel.
12/13/2010 2:09	Founders Residence Hall	Alarm-Fire, Simplex System	Founders Dwing alarm activated. Someone had pulled the pull station located on first floor of Dwing lounge. CSO assisted and reset system.
12/14/2010 19:36	Royer Residence Hall	Alarm Fire Trouble Simplex	Smoke detector activated due to dirty detector. CSO assisted and reset panel.
12/16/2010 1:46	Schreiber Quadrangle	Alarm Fire Simplex System	Alarm activated for no apparent reason. CSO could not silence audible alarm. Director contacted to assist.
12/20/2010 1:24	International House 604 S Mt Joy St	Alarm-Fire, Simplex System	Fire alarm activated in International House due to cooking. CSOs assisted and reset alarm.
12/20/2010 10:54	Brinser Residence Hall	Alarm Fire Simplex	Alarm activated by cleaning in bathrooms. CSO assisted.