

2011 Fire Alarm Log

Incident Date	Building	Incident Details
1/2/2011 0:00	Founders Residence Hall	Alarm activated for no apparent reason. CSO assisted and reset.
1/10/2011 8:50	Schlosser Residence Hall	CO2 detector activated in Schlosser. Cause not determined.
1/10/2011 8:54	High Library	High library fire trouble. CSO assisted and found nothing. System reset.
1/14/2011 10:13	Steinman Hall	Techs grinding pipes set off alarm in Steinman. CSOs assisted and reset alarm.
1/17/2011 17:56	Schlosser Residence Hall	Detector activated by cooking in Schlosser AC apartment. CSO assisted and reset alarm.
1/17/2011 18:57	Vera Hackman Apartments	Dectector activated in Hackman North by cooking. CSO assisted and reset alarm.
1/20/2011 17:45	Vera Hackman Apartments	Detector activated in Hackman S by cooking. CSO assisted and reset alarm.
1/27/2011 4:20	Campus Security	Smoke detector activated in Hackman North 258 due to burned food. CSO assisted and system was reset.
1/28/2011 9:34	Steinman Hall	Dust from ES cleaning caused alarm to be activated. CSO assisted and reset.
1/30/2011 8:38	International House 604 S M	Alarm activated in International House. CSO assisted and foundn nothing. System reset.
1/30/2011 16:59	Royer Residence Hall	Smoke detector activated in Royer by birthday candle. CSO assisted.
2/2/2011 0:07	Founders Residence Hall	Founders Dwing second floor, room 214 smoke detector activated by burnt popcorn. Alarms silenced and reset.
2/2/2011 7:31	Royer Residence Hall	CO detector going off due to emergency generator running. CSO assisted & disabled detector until generator stops running. CSO reset panel.
2/2/2011 10:29	White House 540 S Mt Joy S	RP reported alarm going off. Campus wide power outage.
2/2/2011 10:58	Brinser Residence Hall	Heat alm detector activated in Brinser caused by ventilation system not running due to power outage. CSO assisted and disabled.
2/4/2011 11:27	Brossman Commons	Duct detector in kitchen of Marketplace activated. Audio and visual going off. CSOs assisted. No fire found.
2/5/2011 1:03	Royer Residence Hall	Smoke detector activated in Royer 132. Upon arrival, CSO found a compact toaster that set off the alarm.
2/10/2011 18:57	Wenger Center	Alarm activated by toilet leak flooding through basement in Wenger and running into detector. CSO assisted. ES was contacted.
2/13/2011 19:13	Vera Hackman Apartments	Fire alarm activated due to cooking. CSO assisted and reset alarm.
2/18/2011 13:40	Steinman Hall	Dust in studio activated alarm. CSOs assisted and reset.
2/19/2011 5:05	Schlosser Residence Hall	CSOs responded to alarm in Schlosser. CO2 detector activated. Nothing was found. System was reset.
2/27/2011 20:51	Schlosser Residence Hall	Smoke detector in Schlosser lounge activated by burnt food. CSO assisted and reset system.
3/13/2011 13:08	Brinser Residence Hall	Steam from shower set off alarm in Brinser 2nd floor. CSO assisted and reset panel.
3/13/2011 13:38	Founders Residence Hall	Heat detector set off by steam from showers in Founder Bwing. CSO assisted and reset panel.
3/13/2011 18:51	Myer Residence Hall	Heat detector activated by steam from cooking in Myer 1st floor office. Detector is directly over the stove. CSO assisted and reset system.
3/16/2011 0:16	Founders Residence Hall	Alarm activated in Founders due to steam from shower. CSO assisted and reset alarm.
3/16/2011 12:25	Nicarry Hall	Contractors working in Nicarry basement set off alarm system with dust. CSO assisted and reset.
3/17/2011 1:29	Founders Residence Hall	Alarm activated in Founders by burnt food. CSOs assisted.
3/19/2011 1:13	Royer Residence Hall	Alarm activated in Royer 3rd floor due to food burnt by resident. CSOs assisted and found smoke throughout third floor hallway.
3/23/2011 18:22	Ober Residence Hall	Dirty smoke detector in lobby of Ober 360 activated alarm. CSO assisted.
3/24/2011 21:15	Schreiber Quadrangle	Alarm activated by burnt popcorn. CSO cleared smoke and then reset alarm.
3/25/2011 12:29	Myer Administration	Large rack/tower broke the beam connection in Susquehanna Room causing alarm to activate. Reset when tower was disassembled.
3/25/2011 14:58	Nicarry Hall	Burnt popcorn set off fire alarm in Nicarry 1st floor. CSO assisted, cleared smoke and reset system.
3/27/2011 12:15	Myer Residence Hall	Alarm activated by shower. CSO assisted and reset panel.
4/2/2011 15:18	Myer Residence Hall	Smoke detector activated by steam from shower.
4/2/2011 19:49	Founders Residence Hall	Alarm activated by shower heat. CSO assisted.
4/8/2011 16:11	Residence Life	RP burnt popcorn and set off fire alarm.
4/11/2011 10:19	Founders Residence Hall	Steam from shower activated alarm in Founders. CSO assisted.
4/13/2011 1:05	Vera Hackman Apartments	Smoke detector actiavted in Hackman North. CSO assisted but found no reason for alarm. System reset.
4/17/2011 0:09	Schlosser Residence Hall	Pull station pulled in Schlosser. No one knows who pulled it. CSO checked all and reset pull station and alarm.
4/22/2011 1:07	White House 540 S Mt Joy S	Fire detector activated in White House. CSOs assisted but found no reason for alarm. No one present in house. Panel was reset.
4/27/2011 2:13	Vera Hackman Apartments	Alarm activated in Hackman N 3rd floor. No cause found. All detectors showed green lights.
4/27/2011 3:12	Cedar House 625 S Mt Joy St	CSOs responded to an audible alarm in Cedar House. Alarm was activated by student taking a shoer. System was reset.
4/27/2011 10:16	Schlosser Residence Hall	Smoke from heater activated alarm. MTOC replaced heater motor. Window was opened and system was reset.
4/27/2011 21:56	Founders Residence Hall	Fire alarm activated in Founders A wing shower area. CSOs responded and found nothing. Panel reset and students returned to their rooms.

2011 Fire Alarm Log

Incident Date	Building	Incident Details
4/29/2011 3:27	Vera Hackman Apartments	CSOs responded to supervisory alarm for Hackman. Nothing was found. Alarm was reset.
5/2/2011 21:46	Myer Residence Hall	CSOs responded to Myer 246 for fire alarm. Detector activated by burnt popcorn. System reset.
5/5/2011 7:06	Nicarry Hall	Alarm activated by dust from workers cutting ceiling tiles in Nicarry basement. System reset.
5/8/2011 0:45	Vera Hackman Apartments	Alarm activated due to cooking. CSO reset panels.
5/10/2011 14:12	Residence Life	RP called to tell us that they set off fire alarm with popcorn machine. CSO assisted.
5/11/2011 7:38	High Library	High 1st floor North fire monitor zone. Plant Ops is working and made a hole in a pipe activating alarm. CSO assisted and reset alarm.
5/18/2011 7:41	Schlosser Residence Hall	Alarms were set off by men working there. CSOs assisted.
5/20/2011 15:35	Vera Hackman Apartments	Small oven fire from microwave activated alarm. CSOs responded but found fire out upon arrival.
5/22/2011 10:00	Royer Residence Hall	CO detector set off fire system due to emergency generator running. CSO disabled detector until power outage is over.
5/22/2011 15:06	Founders Residence Hall	Founders Bwing 1st floor mechanical room heat detector activated. M1-75.
5/23/2011 22:08	Brinser Residence Hall	Steam in bathroom from showers activated heat detector. CSO assisted, vented room and reset system.
5/24/2011 8:23	Myer Residence Hall	Painters were sanding walls and dust from sanding caused fire alarms to activate. CSO reset panel.
5/26/2011 0:55	Nicarry Hall	Contractors working in Nicarry basement set off smoke detector. CSO assisted. Alarm was reset.
5/26/2011 14:01	Schlosser Residence Hall	Welders set off alarm. CSO responded and reset.
5/29/2011 7:32	Brinser Residence Hall	Steam from shower caused alarm in Brinser. CSO assisted and opened windows and reset alarm.
5/31/2011 14:02	Brinser Residence Hall	Brinser 1st floor detector was activated by dust from contractors working. CSOs assisted and reset.
6/1/2011 4:19	Vera Hackman Apartments	Alarm activated Hackman Apts. south. CSOs assisted but found no reason for alarm. CSOs reset.
6/7/2011 10:11	Schlosser Residence Hall	Techs were soldering pipes and set off alarm.
6/13/2011 14:40	Ober Residence Hall	Ober basement smoke alarm activated by construction workers. Dust set off alarm. Alarm was reset.
6/17/2011 10:34	Ober Residence Hall	Smoke alarm activated in Ober due to contractors cutting block. CSO assisted but could not reset panel. Disabled point and reset.
6/19/2011 6:59	Brinser Residence Hall	Residents taking showers set off heat detector in bathroom. CSO reset panel.
6/19/2011 7:24	Brinser Residence Hall	Residents taking showers set off heat detector in Brinser. Panel reset.
7/4/2011 9:02	Vera Hackman Apartments	Alarm activated in Hackman North 2nd floor "Elevator Lobby". CSO assisted by nothing was found.
7/6/2011 11:29	Vera Hackman Apartments	A young child pulled south entrance pull station setting off alarm. CSO assisted and reset.
7/6/2011 11:41	High Library	High Library smoke detector activated. CSO assisted but found nothing wrong.
7/11/2011 0:33	Myer Residence Hall	Alarm was set off by shower steam. CSO assisted and reset.
7/11/2011 11:28	Schlosser Residence Hall	Schlosser fire alarm activated. Plant Ops had removed a smoke detector and had set off alarm. CSO assisted and reset.
7/12/2011 1:47	Myer Residence Hall	Alarm caused by dining services turning off G2 breaker in Myer kitchen causing alarm to run on batteries which died. CSOs assisted
7/13/2011 14:54	Schlosser Residence Hall	Welders creating dust in Schlosser activated alarm. CSOs assisted.
7/22/2011 3:17	Founders Residence Hall	Founders Awing shower heat detector activated. CSO assisted but found no problems. System reset.
7/25/2011 5:33	Brossman Commons	RP called for an officer to come to kitchen of Marketplace for a fire. Three hot pads on top of oven vent had caught fire. CSO assisted. EMS system was not activated because there is an exhaust fan directly above the oven.
7/29/2011 11:53	320 Plum Street	Fire alarm activated at 320 Plum Street. CSO assisted but found nothing wrong. Dispatch reset.
7/30/2011 0:43	Vera Hackman Apartments	Occupants cooking bacon set off alarm in Hackman room. CSO assisted and reset panel.
7/31/2011 17:04	Vera Hackman Apartments	Fire alarm activated due to cooking. Alarm did not sound in room. CSO assisted and reset alarm.
8/5/2011 8:13	Zug Memorial Hall	RP reported fire alarm going off in Zug. CSOs assisted. Unknown reason for alarm.
8/6/2011 6:29	Royer Residence Hall	Fire alarm activated due to shower steam. CSOs assisted. All cleared and alarm was reset.
8/6/2011 16:28	Vera Hackman Apartments	Cooking oil set off alarm in VHAN 156. CSO assisted and reset alarm.
8/9/2011 2:18	Steinman Hall	Crock pot of burning wax caused fire in Steinman. CSOs assisted and put fire out.
8/10/2011 14:23	Steinman Hall	Professor mixing substances together caused dust cloud which set off alarm in Steinman.
8/11/2011 8:02	Brinser Residence Hall	Heat detector malfunctioning. Panel would not reset. CSO disabled detector and reset panel.
8/11/2011 20:40	Royer Residence Hall	Panel indicator Royer 3rd floor stairwell smoke detector dirty. CSO reset system.
8/14/2011 17:13	Vera Hackman Apartments	Alarm activated in VHA South 205. CSO assisted. Panel was reset but still showing alarm. Simplex was contacted.
8/16/2011 3:41	Ober Residence Hall	Audible alarm sounding in Ober. CSOs assisted and verified panel. Nothing was found. Panel was reset.
8/16/2011 5:39	Brinser Residence Hall	Detector activated in Brinser. CSO assisted and found no reason for alarm. Alarm reset.
8/16/2011 8:59	Ober Residence Hall	Ober Awing heat detector alarm activated by dust from construction. CSO assisted.

2011 Fire Alarm Log

Incident Date	Building	Incident Details
8/16/2011 11:21	Ober Residence Hall	Alarm activated in Ober for no reason. CSO assisted. (see inc. #11-1215)
8/17/2011 21:13	Vera Hackman Apartments	Smoke detector activated in Hackman 351. CSOs responded and found no problem. CSOs attempted to reset system but failed. Simplex reset.
8/18/2011 15:03	Ober Residence Hall	Smoke detector activated in Ober. CSO assisted and found nothing wrong. CSO reset panel.
8/18/2011 15:09	Founders Residence Hall	Founders 1st floor storage area smoke detector activated. CSO assisted. Head was missing.
8/23/2011 7:08	Zug Memorial Hall	Zug fire alarm activated. CSO assisted and found nothing to cause alarm. CSO could not reset alarm and contacted MTOC. MTOC cleared.
8/24/2011 18:44	Myer Administration	Myer 1 fl Susquehanna Room beam detector activated. Fire monitor zone. CSO assisted. Found nothing wrong.
8/25/2011 19:31	Brossman Commons	BSC 2nd floor corridor building in alarm. Simplex text was cause of alarm.
8/25/2011 22:22	Wenger Center	Fire alarm activated in Wenger. CSO assisted. Alarm caused by Simplex techs testing system.
8/28/2011 18:29	Royer Residence Hall	Fire alarm activated in Royer 322. CSO assisted. System was normal. Panel was reset.
8/28/2011 21:24	High Library	Detector activated in room 208. It activated twice for no cause. CSO disabled it until it is serviced.
8/29/2011 4:44	Zug Memorial Hall	RP reported alarm activated in attic in Zug. two times. Panel was reset.
8/29/2011 7:19	Zug Memorial Hall	Report of fire alarm activated in Zug. CSO assisted disabled zone 5 alarm due to fire panel going off multiple times for no reason. Simplex was contacted.
8/29/2011 8:48	Royer Residence Hall	Alarm activated in Royer by steam from shower. CSO assisted and reset panel after determining the cause.
8/30/2011 19:38	High Library	Alarm activated in High Library 2nd floor. CSO assisted. After 3rd activation, CSO disabled alarm in this area. Simplex was contacted.
8/30/2011 20:48	Royer Residence Hall	Alarm activated by steam from shower. CSO assisted and reset alarm.
8/31/2011 0:00	Off Campus	RP performing fire alarm drills on campus. MTOC contacted for any alarms not received in building.
9/4/2011 16:25	Myer Residence Hall	Shower steam activated alarm in Myer. CSO assisted.
9/6/2011 15:57	High Library	High Library 2nd floor north lobby fire alarm activated two times. CSO assisted and found nothing. CSO disabled zone alarm. Device setting off alarm is in NE corner office 2nd main floor.
9/8/2011 1:36	Schreiber Quadrangle	Burst water pipe flooded basement. No apparent cause for alarm.
9/8/2011 4:44	Ober Residence Hall	Alarm activated in Ober. RP reported the alarm. CSO assisted and changed base and detector head. Alarm was reset.
9/8/2011 14:32	Founders Residence Hall	Steam from shower activated alarm in Founders Awing. Panel reset. Alarm activated again for unknown reason. CSO disabled point and reset alarm.
9/8/2011 14:41	Residence Life	RP reported smoke detector was activated in Res Life by burnt popcorn. CSO assisted.
9/10/2011 1:38	Brinser Residence Hall	Water leaking into detector head activated alarm. CSOs assisted and were unable to locate source of water. MTOC was contacted. Detector was placed in trouble.
9/10/2011 2:56	Ober Residence Hall	Detector activated in Ober basement Bwing by burnt popcorn. CSO assisted. System was reset.
9/11/2011 2:21	Brossman Commons	Alarm was activated by the system on a detector already disabled as CSO was trying to enable other detectors. Panel would not operate properly at first, but eventually CSO was able to silence and reset system.
9/14/2011 11:46	Founders Residence Hall	Smoke detector activated in Founders Cwing. CSOs assisted. Alarm head was broken off and needed to be replaced. CSO brought new head to location and reset alarm.
9/15/2011 15:42	Myer Residence Hall	Alarm was activated by steam from shower in Myer 223. CSO assisted. Alarm was reset.
9/20/2011 16:32	Royer Residence Hall	Steam from shower activated alarm in Royer. AC was notified. System was reset.
9/21/2011 5:16	Schlosser Residence Hall	RP reported smoke coming out of heater unit. CSOs responded and found no heat sources around heating unit. CSOs checked plugs and outlets around heater, removed front cover, and unplugged. MTOC was requested.
9/21/2011 15:47	Myer Residence Hall	Fire alarm activated by burnt popcorn. CSOs assisted.
9/22/2011 11:58	Founders Residence Hall	FH Bwing, 3rd floor shower heat detector/fire alarm. Activated for no apparent reason. CSO responded and found nothing wrong. Attempted reset four times. Unable to reset. Disabled heat detector and reset panel.
9/26/2011 17:42	Ober Residence Hall	Ober Bwing bathroom toilet duct detector activated. CSO assisted. No action required.
9/30/2011 1:37	Vera Hackman Apartments	Hackman North sprinkler monitor/waterflow alarm activated. CSOs assisted and checked area. Nothing was found. MTOCs were contacted and alarm was reset.
10/2/2011 1:42	Founders Residence Hall	Fire alarm activated due to burnt popcorn in Founders B308. CSOs assisted and aired room. CSOs informed students that they could re-enter rooms and they reset alarm.
10/2/2011 2:28	Myer Residence Hall	CSO arrived at Myer 2nd floor to find pull station pulled. No one around seemed to know how it happened. CSO reset pull station and then reset system.
10/10/2011 0:09	Ober Residence Hall	Men's bathroom in Ober heat detector activated alarm due to steam from showers. CSOs assisted.
10/10/2011 19:45	High Library	Fire alarm activated in High Libray. CSO assisted and found nothing.
10/16/2011 2:53	Founders Residence Hall	All units responded to a fire alarm in Founders. It was discovered that someone had lit a plastic grocery bag that was hanging on the coat rack. Two students found the fire and took a water bottle out of the recycle bin, filled it with water, and attempted to put fire out. That is when the alarm went off and dumped all of Founders dorms. No one had information as to how the fire was set.
10/18/2011 21:35	Brossman Commons	Pull station next to Body Shop had been pulled causing alarm. Unknown who had pulled it. CSO assisted and reset system.
10/21/2011 23:21	Royer Residence Hall	Audible alarm in Royer. No strobes were activated. CSO assisted and found no cause for alarm. CSO reset panel.
10/24/2011 18:13	Leffler Chapel	Detector activated by unattended toddler in Leffler chapel. CSO assisted and spoke with parents of toddler and reset alarm system.
10/25/2011 23:47	Vera Hackman Apartments	Burnt food activated alarm in Hackman. Apartment was aired out and system was reset by CSO.
10/28/2011 4:45	Leffler Chapel	Smoke detector activated in Leffler Chapel. CSO responded and found audible/visual alarm in room 110 Electrical Room RTU. CSO found no reason for alarm. System would not reset. CSO disabled monitor point and reset system.
10/29/2011 14:05	Brossman Commons	Hamburgers on back grill at Marketplace possible caused alarm, CSO was unable to reset.

2011 Fire Alarm Log

Incident Date	Building	Incident Details
10/29/2011 17:45	Royer Residence Hall	Royer basement mechanical room detector activated. CSOs assisted and found generator activated alarm.
10/29/2011 18:22	Off Campus	RP reported there were sparks and fire outside at a tree on Cedar Street. Fire department was dispatched. Fire due to transformer in area of Myer/Ober.
10/30/2011 11:38	Brossman Commons	Men working in dining hall activated alarm. CSO assisted.
10/30/2011 22:47	Schlosser Residence Hall	Fire alarm activated by burnt food in dorm. CSOs responded and reset panel.
10/31/2011 16:27	Rose Garden 320 East Orange	Burnt popcorn activated alarm in Rose Garden. CSOs assisted.
11/1/2011 10:12	Ober Residence Hall	Student shook out blanket and caused alarm to activate. CSO assisted and reset alarm.
11/2/2011 22:11	Myer Residence Hall	Burnt food triggered alarm in guest suite in Myer. CSOs responded and vented area. Alarm was reset.
11/4/2011 1:12	Nicarry Hall	Alarm activated in Myer 1st floor kitchen due to food being prepared. CSOs assisted, cleared alarm and allowed students to return to building.
11/5/2011 1:39	Founders Residence Hall	Fire alarm in Hackman basement. CSOs assisted. No water in basement. MTOC thinks it is a flow prpbem. Simplex was contacted to come in.
11/7/2011 0:11	Steinman Hall	Milt Friedly was burning something outside the kiln room and had the door open causing alarm to activate. CSOs responded.
11/11/2011 13:00	Myer Residence Hall	Burnt food in Myer activated fire alarm. CSOs responded.
11/12/2011 23:47	Ober Residence Hall	Burnt popcorn activated fire alarm in Ober 264.
11/14/2011 17:33	Maple House 435 College Av	Fire detector activated in SDLC by cooking. CSO responded and reset alarm.
11/15/2011 13:29	Brinser Residence Hall	Excessively dirty smoke detector activated alarm. CSOs responded and reset system.
11/20/2011 14:40	Founders Residence Hall	Burnt food activated fire alarm in Founders A303. CSO assisted and reset panel.
12/6/2011 7:26	Vera Hackman Apartments	Fire alarm activated by burnt food. CSO responded. Panel was reset after clearing room.
12/9/2011 10:58	Brinser Residence Hall	Smoke detector activated in Brinser 214. CSOs responded but found no apparent reason for alarm. System was reset.
12/19/2011 9:59	Founders Residence Hall	Fire alarm was activated in Founders Bwing by dust. Painter was sanding. CSOs responded and reset alarm.
12/24/2011 14:41	Founders Residence Hall	Fire alarm activated in FHC 2nd floor. CSOs assisted and found nothing but a strong air freshener smell. Panel was reset.